HXD-V1 · MAINTENANCE LOG

Maintenance log

Fill in one block at every check. Work done by hand and readings from your own analyser are not in the unit's records, so we have no other way to know them. Send this log with any enquiry.

Serial number	Location

Date	Total run hours	Status · online tower	Outlet dew point	Inlet · outlet pressure	Checked by
e.g. 2026-11-05	312 h	COOLING · A	-68 °C	10.1 / 10.0 barg	(signature)

Regeneration settings	Leaks · vents · drain	Alarms	Action taken
12 h · 6 h · 150 °C	None found	WA_06 ×1	Emptied liquid trap

Date	Total run hours	Status · online tower	Outlet dew point	Inlet · outlet pressure	Checked by

Regeneration settings	Leaks · vents · drain	Alarms	Action taken

Date	Total run hours	Status · online tower	Outlet dew point	Inlet · outlet pressure	Checked by

Regeneration settings	Leaks · vents · drain	Alarms	Action taken

Date	Total run hours	Status · online tower	Outlet dew point	Inlet · outlet pressure	Checked by

Regeneration settings	Leaks · vents · drain	Alarms	Action taken

Date	Total run hours	Status · online tower	Outlet dew point	Inlet · outlet pressure	Checked by

Regeneration settings	Leaks · vents · drain	Alarms	Action taken

Date	Total run hours	Status · online tower	Outlet dew point	Inlet · outlet pressure	Checked by

Regeneration settings	Leaks · vents · drain	Alarms	Action taken

Date	Total run hours	Status · online tower	Outlet dew point	Inlet · outlet pressure	Checked by

Regeneration settings	Leaks · vents · drain	Alarms	Action taken